

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191614
Address: 1701 SE OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Robb Popp	Partial	Monday, December 20, 2021

Corrective Action Required:

1	Miscellaneous Correction	-CONDUIT FOR (2) LIGHT POLES AT SOUTH ENTRANCE, (6) AT EAST COURTYARD BETWEEN AL AND IL, (2) SOUTHEAST CORNER OF BUILDING
---	-----------------------------	--

Comments: