# CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

# **DEVSERVICES.CITYOFLS.NET**

# **Inspection Summary**

Permit #: PRRES20204103

Address: 129 NW MACKENZIE DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Shawn Hoffman Failed Tuesday, December

Residential 21, 2021

## Corrective Action Required:

1 Miscellaneous

Correction

- Erosion control and methods must be in place until sod is down
- obtain an irrigation permit and submit a back flow certification
- Complete final grading and sod
- provide spark rings on kitchen counter outlets and switches
- Label non GFCI outlet in garage
- Provide spark rings for outlets at bar counter
- Tighten and break off screw to back flow device at water main
- Label non GFCI at sump pump
- Provide clearance of PEX from Bvent above water heater
- Label AV outlet non GFCI in basement
- Provide proper light for patio fan

### **Comments:**