

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215573
Address: 421 NW KAYLEA CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Residential	Michael Harkins	Passed	Tuesday, December 21, 2021

Informational:	
1 Misc	3RD PARTY DRILLED PIERS BY DEREK PEREZ @ EVERSTEAD SIGNED & SEALED BY BRADLEY HUXOL 18" PIER FOUNDATION PER APPROVED PLAN SIZE 18" X DEPTH 6' - 10' BEARING ON LIMESTONE

Comments: