

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212525
Address: 1813 SW SAGE CANYON RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Patrick Schonfeldt	Failed	Tuesday, December 21, 2021

Corrective Action Required:

1	Misc	-Gas pressure 7 psi, must maintain 10 psi for test 12-16-21- NOT READY, PRESSURE AT 5.5 PSI 12/21/21 - NOT READY, PRESSURE AT 5 PSI
---	------	---

Comments: