

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212525
Address: 1813 SW SAGE CANYON RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Not Ready	Tuesday, December 21, 2021

Corrective Action Required:

1	Misc	-rafters not tied to ceiling joist and top plate per code, engineer letter-COMplete CORRECTION PER ENGINEERED LETTER -Fireblock deadspace at basement shower -Tighten all anchor bolts at basement
---	------	--

****OK TO INSULATE****

Comments: