

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20211738
Address: 2061 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Michael Harkins	Partial	Tuesday, December 21, 2021

Corrective Action Required:

1	THE FOLLOWING AREAS ARE APPROVED	- 12/1/21 NORTH PATIO LIGHT FIXTURES - - 12/6/21 SOUTH PATIO LIGHT FIXTURES - - 12/7/21 HARD LIDS RESTROOMS & REAR ENTRY AT RESTROOMS OK TO COVER - -12/21/21 HARD LIDS UNDER STAIRWAY, ENTRY VESTIBULE. OK TO COVER -
---	----------------------------------	---

Comments: