

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20211138
Address: 1201 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Line - Coliform Test 1	Ronald Paynter	Partial	Tuesday, December 21, 2021

Informational:	
1 Misc	Dechlorinated the water line. RP 12-20-21
Informational:	
2 Misc	Pulled first samples for Bac T testing and delivered them to Keystone Laboratories for testing. RP 12-21-21

Comments: