

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20214945  
Address: 305 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Residential</b>	Michael Harkins	Failed	Wednesday, December 22, 2021

Corrective Action Required:

1	Miscellaneous Correction	UPLOAD DRILLED PIERS INSPECTION TO PERMIT POUR AT OWN RISK PENDING DRILLED PIER INSPECTION
---	-----------------------------	---

PROVIDE ADDRESS  
UFER LOCATED SOUTH WALL AT STEP DOWN

**Comments:**