

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20214591
Address: 1103 SW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Aggregate Base	Ronald Paynter	Passed	Wednesday, December 22, 2021

Informational:
1 Misc They removed the noncompliance curbing and placed Tensar Triax140 geogrid along with 6 inches of APWA Type 5 rock over the asphalt / curb section of the parking lot. RP 12-21-21

Comments: