

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20214153

Address: 2150 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081
2100 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water - Material Verification	Ronald Paynter	Passed	Wednesday, December 22, 2021

Informational:

1 Misc

Water materials onsite: 6", 8" and 12" C900 pipe, 6" and 8" gate valves, multiple fittings and bend connections and gaskets. Did notice some adapters were wrong, not epoxy coated, they are going to get these replaced through manufacturer. Still waiting to verify 12" butterfly valves, or fire hydrants.

Informational:

2 Misc

They received fire hydrants today. They are Kennedy Guardian K-81D with epoxy base. Still waiting on some tees and 12" gate valve. Informed Matt and Earl that they will need ferrous metal valve risers because all risers look to be in the parking lot. RP 11-15-21

Informational:

3 Misc

All materials meets water specifications. RP 11-22-21

Comments: