

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20210775  
Address: 1201 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Line - Coliform Test 1</b>	Ronald Paynter	Partial	Thursday, December 23, 2021

Informational:	
1 Misc	Dechlorinated the water line. RP 12-20-21
Informational:	
2 Misc	Pulled first samples for Bac T testing and delivered them to Keystone Laboratories for testing. RP 12-21-21
Informational:	
3 Misc	First samples passed testing by Keystone Laboratories. RP 12-22-21

**Comments:**