

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20202008
Address: 2030 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
ADA Inspection	Ronald Paynter	Passed	Thursday, December 23, 2021

Informational:
1 Misc Forms were placed and aggregate was present and compacted. Dowels were drilled into the curbs and the had the proper ADA warning panels. RP 12-15-21

Informational:
2 Misc ADA ramps were installed correctly. RP 12-22-21

Comments: