

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20181586
Address: 1312 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Monday, December 27, 2021

Corrective Action Required:

1	Misc	-Remove all debris from storm inlet -Provide full support underneath west deck post -Install water hammering arrestor for dishwasher -Install anti backflow device at basement hose bib
---	------	--

****12/27-No one is at home. The house is currently occupied without an issued certificate of occupancy, in violation of the city ordinance. Please correct the above deficiencies and schedule an inspection as soon as possible.**

Comments: