

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212483
Address: 2114 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Michael Harkins	Not Ready	Monday, December 27, 2021

Corrective Action Required:

1	Miscellaneous Correction	PROVIDE MINIMUM 10 PSI FOR 15 MINUTES 12/27/21 0 PSI Michael Harkins 12/27/2021 9:57 AM
---	--------------------------	--

Comments: