

### **PLANS REVIEW CONDITIONS**

Permit No: PRCOM20214970	Date: December 27, 2021
Project Title: ROOTS SEASONAL CUISINE	Applicant:
Location:	
940 NW PRYOR RD, Unit:M, LEES SUMMIT, MO 64081	AEGIS FIRE PROTECTION LLC
Type of Work:	11936 W 119TH ST #262
Occupancy Group: A-2	OVERLAND PARK, KS 66213
Description: NEW TENANT FINISH FOR RESTAURANT	Primary: (913) 825-0343
Construction Type: Type VA (1 hour)	
Map Page:	

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

#### **Alarm Plan Review**

**Reviewed By: Michael Weissenbach**

**Released for Construction**

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule testing.

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**