

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201

# Temporary Certificate of Occupancy

---

**Permit #:** PRRES20210050  
**Address:** 338 NW AMBERSHAM DR, LEES SUMMIT, MO 64081  
**Inspected On:** Monday, December 27, 2021  
**Inspected By:** Michael Harkins  
**Expiration Date:** 01/27/2022

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Michael Harkins	Temporary C of O	Monday, December 27, 2021

**Corrective Action Required:**

1	Misc	-Sidewalk inspection needs completed -complete final grade and sod. -check water meter at time of final grade and sod -splash box's and sump pump discharge to extend 36" from foundation -obtain lawn irrigation permit & submit backflow certification -gutters to be completed
---	------	--