

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20210050
Address: 338 NW AMBERSHAM DR, LEES SUMMIT, MO 64081
Inspected On: Monday, December 27, 2021
Inspected By: Michael Harkins
Expiration Date: 01/27/2022

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Temporary C of O	Monday, December 27, 2021

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | -Sidewalk inspection needs completed
-complete final grade and sod.
-check water meter at time of final grade and sod
-splash box's and sump pump discharge to extend 36" from foundation
-obtain lawn irrigation permit & submit backflow certification
-gutters to be completed |
|---|------|--|