



### **PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20210533	Date:	December 27, 2021
Project Title:	COLDWATER COMMUNITY CENTER	Applicant:	
Location:	838 SW BLUE PKWY, LEES SUMMIT, MO 64063		
Type of Work:			MIDWEST ALARM SERVICES
Occupancy Group:	B		1910 E KIMBERLY RD STE 200
Description:	CHANGE OF TENANT FOR FOOD		DAVENPORT, IA 52807
	PANTRY WITH KITCHEN AND STORAGE AREAS	Primary:	(913) 915-6143
Construction Type:	Type IIB (Unprotected)		
Map Page:			

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

#### **Alarm Plan Review**

**Reviewed By: Michael Weissenbach**

**Released for Construction**

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule a test.

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**