

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20212339  
Address: 1033 SW ARMIE ST, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Shawn Hoffman	Failed	Monday, December 27, 2021

Corrective Action Required:

2	Miscellaneous Correction	<ul style="list-style-type: none"><li>-Seal penetration top plate near garage door</li><li>- Provide anchor bolts garage sill plate</li><li>- Complete vent ductwork 2nd floor master bathroom</li><li>- Complete vent ductwork 2nd floor back bathroom</li><li>- Strap top plate bedroom 3 at triple LVL</li><li>- Strap top plate bedroom 2 at triple LVL</li><li>- Add hangers to joist header at master bedroom at LVL</li><li>- Complete vent for shower basement</li></ul>
---	--------------------------	--

**Comments:**