

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20211138  
Address: 1201 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Line - Coliform Test 2</b>	Ronald Paynter	Passed	Monday, December 27, 2021

Informational:  
1      Misc      Pulled second samples for Bac T and delivered them to Keystone Laboratories for testing. Still waiting to hear back on the results from the first samples. RP 12-22-21

Informational:  
2      Misc      Samples have passed Bac T testing. RP 12-27-21

**Comments:**