

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211915
Address: 2366 SW OLD PORT RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Tuesday, December 28, 2021

Corrective Action Required:

- | | | |
|---|--------------------------|--|
| 1 | Miscellaneous Correction | <ul style="list-style-type: none">- Submit as graded plot plan- Sidewalk and driveway inspection pending- gutters and down spouts- Final grading and sod- Splash blocks- Obtain irrigation permit and submit back flow certification- Maintain erosion control until sod is in place- Provide ladder for egress window basement- Complete A/C disconnect |
|---|--------------------------|--|

Comments: