

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214193
Address: 501 NE WENONGA PL, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Khanh Nguyen	Failed	Tuesday, December 28, 2021

Corrective Action Required:

1	Misc	-Provide a listed grounding clamp to rebar. The acorn grounding clamp is only listed for grounding connection of copper conductor to grounding rod. Hint: Notice the contact of dissimilar metals (copper GEC to iron)when use the acorn grounding clamp to rebar
---	------	---

Comments: