



ASTM D698

Alpha Omega Geotech, Inc
1701 State Avenue
Kansas City, KS 66102
Phone: 913-371-0000


Client:
LSPH Investors, LLC
7939 Floyd Street
Overland Park, KS 66204

Project:
21-390F
Chipotle Lee's Summit
1130 SE Oldham Pkwy
Lee's Summit, MO

General Information

Sample Date:	12/21/2021	Sample Number:	3282
Sample From:	Stockpile	Sampling Method:	Stockpile ASTM D75/AASHTO T2
Location Details:		Drive Thru of Chipotle	
Location:	Base Fill	Technician:	Curtis, Cody

Test Results

Soil Classification:	GP-GM Crushed limestone with fines	Color of Soil:	Gray
Sample Preparation Method Used:		Dry	
Compaction Method Used:	C (ASTM D698)	Type of Rammer Used:	Mechanical
Proctor Curve: 		Specific Gravity of Sample:	2.59
		Maximum Dry Density:	119.7
		Optimum Moisture:	7.5
		Oversize Correction Needed:	Yes
		Corrected Maximum Dry Density:	126.6
		Corrected Optimum Moisture:	5.9
		Test Completed Date:	12/27/2021
		Test Completed By:	Burdick, DJ