

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20212477  
Address: 1515 SW ARBOR VALLEY DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Wednesday, December 29, 2021

Informational:

1 Misc

- GARAGE PORTAL EXTERIOR OK TO COVER

Corrective Action Required:

2 Misc

-Provide lateral bracing for trusses per plans  
-fireblock above SW den window  
-fireblock at steel beam furr down exterior daylight wall in basement den  
-fireblock vertical every 10' between foundation/framing at finished basement  
-(2) 2x10 header at basement den window per plans  
-solid block between joists at cantilevers

**Comments:**