

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212483
Address: 2114 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Wednesday, December 29, 2021

Corrective Action Required:

1 Misc

- FB soffit line, rim joist, and furout for insulation at mechanical in 2 car bay
- Seal fire block top of ductwork.pantry
- Provide protection plate at 3" waste pipe at ceiling living room
- Complete through bolts on I beam at dining room
- Secure bottom of steel post at stairway
- Provide LIBs per plan
- Complete vent ductwork upstairs
- Seal floor penetration second floor fireplace
- Provide protection plate at sump discharge line in stair landing
- Flash and install missing windows

Comments: