

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215351
Address: 1512 SW SUGAR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Residential	Mitchell Schwarz	Failed	Wednesday, December 29, 2021

Corrective Action Required:

1	Misc	-provide handrail at basement steps -spark rings at kitchen area backsplash -mechanical room must comply with code section G2407 (304) of the IRC
---	------	---

Informational:

2	Misc
---	------

Comments: