

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20211697  
Address: 4737 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Failed	Wednesday, December 29, 2021

Corrective Action Required:

1	Misc	-Frame CSPF walls at rear dining per S2.1 **need to nail siding per plan  -Provide full support I beam at pantry **right side. not done  -Fb b-vent space from soffit  -Shim gaps below studs and sill plate at mid-stair landing **excessive gap between foundation wall and sill plate  -Nail stair wall corner studs per code  -Support lvl hip above bedroom 5  -Provide 1" space around b-vent at insulation shield  -Provide insulation shield for upper floor furnace flue  -Brace interior walls on 2nd fl per plan  **OK TO INSULATE
---	------	--

**Comments:**