

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSITE20180219  
Address: 201 NW KESSLER DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                         | Inspector:    | Outcome: | Date:                      |
|-------------------------------------|---------------|----------|----------------------------|
| <b>Fire Line - Hydrostatic Test</b> | Steve Robbins | Passed   | Tuesday, December 21, 2021 |

Informational:  
1 PW-Misc The hydrostatic pressure twst for the 4" service line has been passed. They are planning on possibly doing the fire line today.Steve Robbins 10/01/2018 9:51 AM

Informational:  
2 PW-Misc The hydrostatic pressure test for fire line has passed 200psi for 2hrs. This is a partial completion of the water lines that have been installed.Steve Robbins 10/04/2018 7:54 AM

Informational:  
3 Misc Hydrostatic pressure test of 8 inch fire line passed 200 PSI for over 2 hrs. Still need to test the 4 inch domestic line. RP 4/29/19

**Comments:**