



PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #:PRPWRW20215998, Public Works Right of Way Permit
Address: 1600 SW BUCKTHORN ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Site Visit Inspection	Matt Munger	Passed	Thursday, December 30, 2021

Corrective Action Required

1 Misc

Site Visit - The work appears to be complete. The street crossing depth marks indicate the depth of bore meets our minimum 3ft requirement for street crossings. This is a newly developed area grass has not developed in most areas. Closing this out.

Comments: