

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210540
Address: 4413 SW TANZANITE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Thursday, December 30, 2021

Corrective Action Required:

1	Misc	-splash blocks and sump pump discharge to extend 36" from foundation -grade less than 6" from siding, several locations throughout -spark ring on outlets where not code compliant see fridge, above fireplace -obtain lawn irrigation permit -resolve outstanding inspection fee(s) before final c of o
---	------	--

Comments: