

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20211582  
Address: 4417 SW ALABASTER CIR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Patrick Schonfeldt	Failed	Thursday, December 30, 2021

Corrective Action Required:

1	Misc	-Resolve outstanding inspection fees before final c of o -Submit revised plot plan for changes concerning sidewalk at front of property, per Steve Robbins -min 6" clearance required between sod and siding - see rear of house
---	------	--

OK FOR TCO - TCO EXPIRES 1/17/22

**Comments:**