

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20214830
Address: 419 SW WARD RD, Unit:A, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Michael Harkins	Failed	Thursday, December 30, 2021

Corrective Action Required:

1	Miscellaneous Correction	Phase 1 Provide grommets pex line to ice maker break room Provide midpoint support vertical DWV 2" & smaller Pressure steady at 5 psi DWV
---	--------------------------	--

Comments: