

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212858
Address: 2110 SW RUTHERFORD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sewer Service Inspection - R	Patrick Schonfeldt	Passed	Thursday, December 30, 2021

Informational:	
1 Misc	OK SEWER LINE, DO NOT COVER, FOOTING HAS BEEN UNDERMINED FOR EXCAVATION, HAVE ENGINEER ADDRESS FOOTING

Comments: