

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212858
Address: 2110 SW RUTHERFORD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Patrick Schonfeldt	Failed	Thursday, December 30, 2021

Corrective Action Required:

1	Misc	FOOTING HAS BEEN UNDERMINED FOR SEWER LINE EXCAVATION, DO NOT COVER, HAVE ENGINEER ADDRESS FOOTING
---	------	--

Comments: