

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215570
Address: 2361 SW HICKORY LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Patrick Schonfeldt	Failed	Monday, January 03, 2022

Corrective Action Required:

1	Misc	-CONNECT INTERIOR DRAIN TILE TO SUMP PIT -UNCOVER GRAVEL/SNOW FROM BASEMENT BATHROOM GROUP LINES TO ALLOW FOR INSPECTION
---	------	--

Comments: