

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20211433  
Address: 107 NW JOSHUA DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Michael Harkins	Failed	Tuesday, January 04, 2022

Corrective Action Required:

1	Miscellaneous Correction	Pay not ready fees No pier inspection 3rd party footing ? Submit back flow certification lawn irrigation permit Complete downspout front stoop Garage door shall be self closing @ self latching Provide weatherstripping self closing door Handrail garage shall support 200 lbs of force Sump shall discharge 36" from foundation wall Splash block shall discharge water 36" from foundation
---	--------------------------	---

Comments: