

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20213955

Address: 2103 SW OSAGE DR, LEES SUMMIT, MO 640822105 SW OSAGE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                             | Inspector:         | Outcome: | Date:                     |
|---|--------------------|----------|---------------------------|
| <b>Footing Inspection - Residential</b> | Patrick Schonfeldt | Failed   | Tuesday, January 04, 2022 |

Corrective Action Required:

|   |      |  |
|---|------|--|
| 1 | Misc | FOOTING HAS BEEN UNDERMINED FOR SEWER LINE EXCAVATION, DO NOT COVER, HAVE ENGINEER ADDRESS |
|---|------|--|

Comments: