

DEVELOPMENT SERVICES

Residential Plan Review

January 04, 2022

CLAYTON PROPERTIES GROUP, INC
120 SE 30TH ST
LEES SUMMIT, MO 64082
(816) 246-6700

Permit No: PRRES20220006
Plan Name:
Project Address: 3538 SE CORBIN DR, LEES SUMMIT, MO 64082
Parcel Number: 70500070500000000
Location: COBEY CREEK - 1ST PLAT---LOT 155
Type of Work: NEW SINGLE FAMILY
Occupancy Group: RESIDENTIAL, ONE- AND TWO-FAMILY
Description: NEW HOUSE - UNFINISHED BASEMENT - UNCOVERED DECK

Revisions Required

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and provide two (2) copies of any revised sheets and/or additional information.

Development Services Department (816) 969-1200

Plot Plan Review **Reviewed By: Kim Brennan** **Rejected**

1. Minimum Building Opening Elevation (MBOE) and location on structure must be provided on the plot plan.

It is my understanding that the MBOE's in this subdivision were removed for lots 1-7 and 13-29.

2. A as-graded plot plan per Section 7-160, Code of Ordinances, is required prior to occupancy.

Residential Plan Review **Reviewed By: Kim Brennan** **Approved**

Planning Review RES **Reviewed By:** **Not Required**

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.

Residential Area:	
Residential, Decks	120
Residential, garage	670
Residential, Living Area (Not Finished Basement)	1858

Residential, Un-Finished basements		722	
Roofing Material		Number of Bathrooms	2.5
Number of Bedrooms	4	Number of Stories	2
Number of Living Units	1	Total Living Area	1858
Sewer Connection Fee	14		