

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20211038
Address: 1529 SW GEORGETOWN DR, LEES SUMMIT, MO 64082
Inspected On: Wednesday, January 05, 2022
Inspected By: Mitchell Schwarz
Expiration Date:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Temporary C of O	Wednesday, January 05, 2022

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | -Completed final grade and sod
-splash blocks and sump pump discharge to be 36" from foundation

-check water meter & siding from ground at time of final grade and sod
-obtain irrigation permit
-flood light at back of house |
|---|------|--|