

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20212128
Address: 150 NW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Michael Harkins	Partial	Wednesday, January 05, 2022

Corrective Action Required:

1	Miscellaneous Correction	PROVIDE BOCA PLATES THROUGHOUT PROVIDE MID POINT SUPPORT VERTICAL DWV 2" & SMALLER COMPLETE ELECTRICAL NORTH WALL
---	--------------------------	---

Comments: