

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191614
Address: 1701 SE OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Robb Popp	Partial	Wednesday, January 05, 2022

Corrective Action Required:

1	Misc	-Procide (3) wraps at ceiling wire -Support grid max 4' OC -Complete electrical, support mc and lights -Complete duct at dishwasher hood
---	------	---

Kitchen ok for skirts at dishwasher and hood

Comments: