

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20210648  
Address: 3114 SW BLUE RIBBON ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Failed	Wednesday, January 05, 2022

Corrective Action Required:

1	Misc	<p>*Pay all fees*</p> <ul style="list-style-type: none"><li>-complete sidewalk inspection</li><li>-Complete hardware at front door</li><li>-garage outlets must comply with code section E3901.9 of the IRC</li><li>-label all non GFCI outlets</li><li>-complete cook top ventilation in island</li><li>-complete fire place install</li><li>-sheer off screw at anti Siphon device in basement</li><li>-A/c breaker incorrect size, lockout on oven breaker</li></ul>
---	------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: