

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212478
Address: 3200 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Wednesday, January 05, 2022

Informational:	
1 Misc	-GARAGE PORTAL EXTERIOR ONLY OK TO COVER
Corrective Action Required:	
2 Misc	-address overbored stud for SE cable at south garage wall, FIX TO ENGINEERED LETTER SPECIFICATIONS -Install sliding glass door -unable to inspect trusses covered patio due
	Okay to insulate

Comments: