

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211820
Address: 1867 NE PARK RIDGE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Thursday, January 06, 2022

Corrective Action Required:

1	Misc	-Complete installing window, trimming, and flashings -Shall protect gas csst line at fireplace box entry with proper sleeve, not foam sleeve please **OK TO INSULATE
---	------	--

Comments: