

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211772
Address: 314 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Failed	Thursday, January 06, 2022

Corrective Action Required:

1	Miscellaneous Correction	Driveway inspection still pending Obtain lawn irrigation permit & submit back-flow certification RIM JOIST SHALL BE INSULATED (2018 IRC TABLE N1102.4.1.1)
---	--------------------------	---

Comments: