

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204351
Address: 2529 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Not Ready	Friday, January 07, 2022

Corrective Action Required:

1	Misc	INSPECTION DENIED DUE TO DEFICIENT EROSION CONTROL AND NO PREMISES IDENTIFICATION POSTED Mitchell Schwarz 01/07/2022 10:31 AM
---	------	--

Comments: