

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212318
Address: 106 NW JOSHUA DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Friday, January 07, 2022

Corrective Action Required:

1	Miscellaneous Correction	NO INSPECTION
---	--------------------------	---------------

NO CITY APPROVED PLANS ON SITE

Corrective Action Required:

2	Misc	-premise identification to be posted -anchor bolts to be in the middle 1/3 of bottom plate -provide hangers per plans threw out, tjc35,tjc57 truss corners plus deck -fire block ends Furr down gas line at stairway -Insulate cantilever & solid block above SGD basement
---	------	--

Comments: