

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20214591
Address: 1103 SW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Michael Harkins	Failed	Friday, January 07, 2022

Corrective Action Required:

1	Miscellaneous Correction	PROVIDE STRUCTURAL STRAPS AT ROOF DRAINS TOP PLATE PROVIDE BOCA PLATES AT ROOF DRAINS FIRE CAULK UPWARD PENETRATIONS : OK TO ROCK ABOVE STORE FRONT WINDOWS :
---	--------------------------	--

Comments: