

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215699
Address: 1917 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Patrick Schonfeldt	Not Ready	Monday, January 10, 2022

Corrective Action Required:
1 Misc INSPECTION DENIED

-ADDRESS EROSION CONTROL ON LOT, CLEAN ALL GRAVEL FROM STREET-

Comments: