

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210875
Address: 3057 NW THOREAU LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Not Ready	Monday, January 10, 2022

Corrective Action Required:

1	Misc	Garage portal ok. Truss screws over covered deck, ok
---	------	---

Corrective Action Required:

2	Misc	Not Ready -no truss package - no fire blocking done provide city stamped truss package and plans
---	------	---

Comments: